



Bureau of Energy Efficiency



सत्यमेव जयते
Government of India
Ministry of Power



german
cooperation
DEUTSCHE ZUSAMMENARBEIT

giz Deutsche Gesellschaft
für Internationale
Zusammenarbeit (GIZ) GmbH


ANGAN

Augmenting Nature by Green Affordable New-habitat

A Courtyard for Revolutionary Change in Building Energy Efficiency

An International Conference on Building Energy Efficiency

9th-11th September, 2019 | Hotel The LaLiT, New Delhi





Bureau of Energy Efficiency



सत्यमेव जयते
Government of India
Ministry of Power



giz Deutsche Gesellschaft
für Internationale
Zusammenarbeit (GIZ) GmbH

THIS PRESENTATION WAS SHARED BY

Ar. Poorva Keskar

Director, VK:e environmental, Pune

FOR THE SESSION:

“Emerging Construction Practices & Technologies”

DURING ANGAN 2019

Knowledge Partner

teri | THE ENERGY AND
RESOURCES INSTITUTE
Creating Innovative Solutions for a Sustainable Future

Event Partner

TEC INDIA TM
EVENT & BRAND MANAGEMENT CO.

ANGAN

Construction Practices & Technologies for Energy Efficiency in buildings

Dr. Poorva Keskar

Director



Reduce

Architectural design approach for energy demand reduction through:

- Orientation
- Spatial planning
- Design for daylighting
- Energy efficient building envelope
- Using appropriate materials

Re-Think


Alternative Active Energy Systems such as

- Geo-thermal Cooling
- Evaporative Cooling

System Efficiencies

Recycle & Reuse


- ***Recycle and Reuse of construction waste materials***
- ***Recycle and Reuse of treated water***



Re-generate

Energy generation through installation of Renewable Energy Systems

The Project



Enpro Headquarters is a proposed office building in Pimpri, Pune having a built up area of around 4700sqm




Options for Shading Devices



OPTION 1

Aluminium JALI with full height windows on all sides



OPTION 2

Vertical Fins with full height windows on all sides



OPTION 3


Optimized WWR with shading devices as per orientation

Good shading
Obstructed views
Increased costs

Good shading
Obstructed views
Increased costs

Good shading
Good Views
Optimized costs due to optimized glazing area and effective shading devices

Selection of appropriate glazing



A representative energy simulation has been conducted to understand the impact of glazing selection along with the proposed Jali on the cooling loads.


The combination of clear DGU and Jali has reduced the sensible cooling loads by 12% and has reduced the overall energy consumption by 7%

Simultaneously, the daylight availability was checked


DAYLIGHT ANALYSIS

Input Parameters for Simulation:


Sky condition: 9000 Lux
 (Sunny without Sun)
 Working plane : 0.75 meter
 Time : 21 September
 (10am, 12pm, 3pm)



South facing space considered for daylight analysis




Window Glass: SGU with 70%VLT



perforated shading pane considered for daylight analysis
 percentage of voids for this module is 21.5%

Analysis Grid

RAD Illuminance
 Contour Range: 100 - 1000 Lux
 In Steps of: 50 Lux
 © ECOTECH






Average Value: 295.14 Lux
 Visible Nodes: 320

Time of Simulation: 21Sept – 10:00 AM
 Average Value : 295.14 Lux

Difference in Daylight Analysis due to Provision of False Ceiling and Furniture Option A,L and option 2

Table Showing change in Daylight percentage due to interior objects

17th Sept 9 am			
Type of Option	Without Ceiling	With Ceiling	Options
Option A (22% Voids)	36.0%	45.7%	
Option L (59.6% Voids)	74.6%	80.09%	
Option 2 (Louvers)	66.10%	98.60%	





Image showing Ceiling and furniture

In earlier simulations Ceiling was provided at 3.9m above finished floor .

In option 2 it was observed that there is a difference in illumination after providing furniture and ceiling at 3.25m.

Ceiling Reflection 80 % and furniture Reflection 55%

Earth Air Tunnel Cooling



Schematic showing EAT
(Source : BEEP)



Actual Site Photographs

600 mm dia concrete pipes running in two loops.


Loop 1 – 120 meters

Loop 2 – 131 meters

Avg – 4.5 meters depth

An extract fan provides air to Badminton Hall, Reception and Cafeteria.


Air Delivery Temperature of 27 to 20 °C is expected




Combination of Active cooling strategies

- **Evaporative cooling** : for all open office areas
- **Earth Air Tunnel** : for Badminton hall, reception and cafeteria
- **Air cooled VRV** : for enclosed spaces such as meeting rooms, cabins, auditorium and experience zone

These strategies have helped in reducing cooling energy demand by more than 50% as compared to conventional central air-conditioning system.





$$\text{EPI Ratio} = \frac{\text{EPI of Proposed Case}}{\text{EPI of Standard case}} = 0.56 < 1$$



Solar PV installation of 168KW

Estimated EPI (including equipment) : 65 kWh/sqm/yr

Annual energy consumption : 305,500 kWh/yr

Annual energy generation : 2,57,544 kWh/yr


The energy generation from the solar panels offsets 84% of the total energy consumption of the building, thus the project is a NEAR NET ZERO ENERGY project.

Opaque Envelope

Overall Wall Assembly U-value

Flyocrete AAC blocks have been used for wall assembly of the buildings along with external cement plaster and internal gypsum plaster.

The **U-value for wall assembly as per IGBC is 1.80 W/m²K** and the **U-value for the project is 1.12 W/m²K**




U-Value Calculations				
	Wall Assembly	Thickness	K-Value	R-Value
Layer - 1	External Surfaces (fo)			0.123
Layer - 2	15 mm thk External Plaster	0.015	0.72	0.021
Layer - 3	Flyocrete – AAC Block	0.15	0.24	0.625
Layer - 4	12 mm thk Gypsum internal Plaster	0.012	0.461	0.026
Layer - 5	Internal Surfaces (fi)			0.1
Total Resistance				0.89
U-Value of the proposed Wall Assembly in W/m²K				1.12
U value suggested by the IGBC in W/m²K				1.80

Overall Roof Assembly U-value

The project has made use of **XPS insulation boards** for the roof in order to avoid excessive heat gain as maximum heat enters the building from the roof area.

Additionally **high SRI tiles** have been laid on the terrace for the cool roof effect.



U-Value Calculations				
	Roof Assembly	Thickness	K-Value	R-Value
Layer - 1	External Surfaces (fo)			0.044
Layer - 1	5mm thick Tiles	0.005	0.18	0.028
Layer - 3	Cement Screed	0.03	0.71	0.042
Layer - 4	Thermal Insulation – XPS	0.05	0.028	1.786
Layer - 4	Brick Bat Coba	0.15	0.81	0.185
Layer - 5	RCC Slab	0.15	1.58	0.095
Layer - 6	12 mm thk Gypsum internal Plaster	0.012	0.461	0.026
Layer - 7	Internal Surfaces (fi)			0.105
Total Resistance				2.31
U-Value of the proposed Roof Assembly in W/m²K				0.43
U value suggested by the IGBC in W/m²K				0.50

Compliance with ECBC-R

As per ECBC R the Thermal transmittance of roof shall comply with maximum U roof value of 1.2 W/sqmK

For this project the roof thermal transmittance is as follows :

$$U_{\text{roof}} = 1/1470.7 \times (0.43 \times 1470.7) \\ = 0.43 \text{ W/sqmK}$$


Thus the project complies with the thermal transmittance of roof as per R-ECBC



Residential Envelope Transmittance Value (RETV) as per R-ECBC for four climate zone should not be greater than 15W/m2.

Equation 1	a*Area of opaque*U-value of opaque*w	6942.48
Equation 2	b*Area of non opaque*U-value of non-opaque*w	2358.09
Equation 3	c*Area of non opaque*SHGC*w	16550.93
Equation 4	Eq 1 + Eq 2 + Eq 3	25851.50
RETV =	(1/Aenvelope)* Eq4	13.81
RETV compliance (15 W/m2)		YES

Envelope Design-Fenestrations



Glass Selection and Shading Devices

The project has shown compliance by using a combination of double glazed unit glass and shading devices. The project complies with the requirements of SHGC as per IGBC.


The adjusted SHGC is calculated as per the ECBC methods

SHGC CALCULATIONS – SUMMARY				
Wing	Orientation	SHGC of Glass	Adjusted SHGC	SHGC Recommended by IGBC
WING A & B	East	0.56	0.28	0.32
	West	0.56	0.19	0.32
WING C & D	North	0.56	0.24	0.32
	South	0.56	0.26	0.32
WING E & F	East	0.56	0.24	0.32
	West	0.56	0.19	0.32

Solar PV Installation

The project has installed a total of **22 kW** of solar photovoltaic cells on the roof tops of all the buildings. The solar photovoltaic cells help to cater to the total annual common area lighting consumption of the project.

Sr No.	Energy Consumption	Value in kWh
1	Total common area lighting consumption	32,844
2	Total generation of installed on-site renewable energy systems	33,726
3	Percentage of power generation using solar PVs	102.68 %



Affordability



Thankyou